

FORM – C2
[See sub-rule (1) of rule 5]
Test Report of Lift Installation

To,

The Inspector of Lifts, Escalators and Passenger conveyors,

.....

Sir,

Sub: Test report of lift installation, rope etc -reg.

As required by sub-rule (1) rule 5 of the Karnataka Lifts, Escalators and passenger conveyors Rules, 2015, I/we here by certify that the Lift /s installed at..... and owned by is/are under my/our maintenance.

We have conducted the following checks/examination/tests and the results are here under.

Sl. No	Particulars	Details of tests performed and results	
1	Distinguishing number or mark (if any) and description sufficient to identify the lifting machine, chains, rope or the lifting tackle	Type of lift: Serial No: Make:	
2	Date and number of the certificate relating to any test and examination made ; (a) Electric traction lifts	<p><u>(a) Annual Tests</u></p> <p>(1) Buffer tests (2) Governor and safety (3) Test of slack rope device or winding drum machine (4) Test of normal terminal stopping device (5) Test of final terminal stopping device (6) Standby power operation (7) Power door operation closing force and speed (8) Broken rope, tape or chain switch (9) Electrical protective devices test (10) Ascending car and unintended motion device test</p> <p><u>(b) Five year tests.-</u></p> <p>(1) Governor test (over speed switch setting and Governor trip setting) (2) Types "A", "B" and "C" safeties (3) power test (4) Test of buffer (5) Brake for passenger elevators and freight elevators authorized to carry passengers</p>	

		(6) Test of emergency terminal stopping device (speed limiting device) (7) Test of leveling speed and leveling zone Inner landing zone test (static controls)	
	(b) Hydraulic Elevator tests	(a) Annual Tests (1) Working pressure and Relief valve (2) Pressure test of Flexible hose and fitting (3) Hydraulic cylinder leak test (4) Terminal speed reducing (5) Standby power operation (6) Power operation of doors (7) Normal terminal stopping device (8) Low oil and RPR protection (9) Supply line and valve (10) Slack rope device (11) Emergency operation FFS (12) Pressure switch (13) Buffers (14) Car safety (15) Governor (b) Five year tests (1) Car buffer (2) Plunger gripper (3) Over speed valve (seismic valve)	
3	Date of periodical examination made		
4	Particulars of any defects affecting the safe working load found at such through examination or after annealing and of the steps taken to remedy such defect.		

We certify that on....., we have thoroughly examined the lift/s and that above is a correct report of the result.

Further the installation of the aforesaid Lift/s satisfies the entire requirement as laid down under the Karnataka Lifts, Escalators and passenger conveyors Act, 2012, and rules made there under. I/we maintain log book as required under rule 9(5) of Karnataka Lifts, Escalators and passenger conveyors Rules, 2015.

Date:

Signature of the registered person

Registration No and validity